


## PLUMBING DETAILS



Wet venting is limited to vertical drainage piping receiving the discharge from the trap arm of one (1) and two (2) fixture unit fixtures that also serve as a vent for not to exceed four (4) fixtures. All wet vented fixtures shall be on the same floor level; provided further, that fixtures with a continuous vent discharging into a wet vent ahalf be on the same floor level as the wet vented fixtures.







VERTICAL WET VENTING

No gas piping shall be installed in or on the ground under any building or structure and all exposed gas piping shall be kept at least six (6) inches (152.4mm) above grade or structure. Concealed, unprotected gas piping may be installed above grade in approved recesses or channels.


Exception: When necessary due to structural conditions, approved type gas piping may be installed in other locations when permission has first been obtained from the Administrative Authority.





Traps for island sinks and similar equipment shall be roughed in above the floor and may be vented by extending the vent as high as possible, but not less than drain board height. The vent is then returned downward and connected to the horizontal sink drain immediately downstream from the vertical fixture drain.

The returned vent shall be connected to the horizontal drain through a Y-branch fitting, (see "b") and shall in addition be provided with a foot vent taken off the verticel fixture vent by meens of a Y-branch fitting immediately below the floor. This foot vent extends to the nearest partition and thence through the roof to the open air, or may be connected to other vents at a point not less than (6) inches (152.4 mm) above the flood level rim of the fixture served.



PLACER COUNTY BUILDING DEPARTMENT SOURCE: IAPMO, UPC ILLUSTRATED TRAINING MANUAL 1991 EDITION

Rev. DATE: August 14, 1992